


- PROVIDE SPEAKERS IN CORRIDORS, OFFICES, BATHROOMS, CONFERENCE ROOMS AND CLASSROOMS, MAXIMUM 20' SPACING.
- MOUNT ACCESS POINTS (AP)TO CEILING. LOCATE ACCESS POINTS FOR OPTIMUM COVERAGE.

DRAWING KEYNOTES


- LOCATE CENTERED ABOVE WHITEBOARD.
- 2 84" AFF.







GRAPHIC SCALE

CHECK GRAPHIC SCALE BEFORE USING








- PROVIDE SPEAKERS IN CORRIDORS AND CLASSROOMS, MAXIMUM 20' SPACING.
- MOUNT ACCESS POINTS (AP)TO CEILING. LOCATE
 ACCESS POINTS FOR OPTIMUM COVERAGE.

DRAWING KEYNOTES

- LOCATE CENTERED OVER WHITEBOARD.
 84° AFF.
- 3 PUSH BUTTON FOR FRONT DOOR RELEASE
- PUSH BUTTON FOR LOCKDOWN, INTERFACE WITH FIRE ALARM SYSTEM TO RELEASE MAGNETIC DOOR HOLDERS. FIELD VERIFY LOCATION WITH OWNER AND ARCHITECT PRIOR TO ROUGH-IN.
- 5 PROVIDE 4"X4" BOX AND 1"C TO VIDEO PRODUCTION ROOM H201A.
- 6 PROVIDE 4"X4" BOX AND 1"C TO PA RACK AT BACK OF AUDITORIUM.
- PROVIDE AN AIPHONE LEM AUDIO HANDS FREE INTERCOM SYSTEM (OR EQUIVALENT) BETWEEN VESTIBULE H100A AND HS OFFICE H101.









GRAPHIC SCALE




1 SECOND FLOOR TECHNOLOGY PART PLAN MS-A ET105 SCALE: 1/8" = 1'-0"

DRAWING NOTES

- PROVIDE SPEAKERS IN CORRIDORS AND CLASSROOMS, MAXIMUM 20' SPACING.
- MOUNT ACCESS POINTS (4P) TO CEILING. LOCATE ACCESS POINTS FOR OPTIMUM COVERAGE.

DRAWING KEYNOTES

- LOCATE CENTERED ABOVE WHITEBOARD.
 84* AFF.
























- PROVIDE SPEAKERS IN CORRIDOR AND CLASSROOMS, MAXIMUM 20' SPACING.
- MOUNT ACCESS POINTS (4P) TO CEILING. LOCATE ACCESS POINTS FOR OPTIMUM COVERAGE.


DRAWING KEYNOTES


- LOCATE CENTERED ABOVE WHITEBOARD.
- 2 84" AFF.





GRAPHIC SCALE






 PROVIDE SPEAKERS IN CORRIDORS, OFFICES, BATHROOMS, CONFERENCE ROOMS AND CLASSROOMS, MAXIMUM 20' SPACING. MOUNT ACCESS POINTS (AP)TO CEILING, LOCATE ACCESS POINTS FOR OPTIMUM COVERAGE.

DRAWING KEYNOTES

LOCATE CENTERED ABOVE WHITEBOARD.
 84* AFF.




















1 CAFETERIAS AND LIBRARY PA SYSTEMS ONE-LINE DIAGRAM
ET503 SCALE: NOT TO SCALE




DIAGRAM NOTE:

1. CONDUIT AND CABLES SHALL BE CONCEALED WITHIN WALLS, CELLING, FLOORS, ETC.

2. PROVIDE CONDUIT FOR CABLES. SIZE PER NEC. MINIMUM CONDUIT SIZE SHALL BE 34*.

4 AUDITORIUM PA SYSTEM ONE-LINE DIAGRAM ET503 SCALE: NOT TO SCALE





DIAGRAM NOTE:

1. PROVIDE CONDUIT FOR CABLES. SIZE PER NEC. MINIMUM CONDUIT SIZE SHALL BE 3/4*.

2 MS GYM PA SYSTEM ONE-LINE DIAGRAM ET503 SCALE: NOT TO SCALE



DAGRAM NOTE:
1. PROVIDE CONDUIT FOR CABLES, SIZE PER NEC, MINIMUM CONDUIT SIZE SHALL BE 34*

3 HS GYM PA SYSTEM ONE-LINE DIAGRAM ET503 SCALE: NOT TO SCALE



2017 82233-AM BAYT LOCALOTHEZ ET, FREUTS BOHOOL, SLECTRICAL VIT, BDAGLE, EXTORT AN